



LAKE COUNTY

FLORIDA

OFFICE OF PROCUREMENT SERVICES
315 WEST MAIN STREET, SUITE 441
PO BOX 7800
TAVARES FL 32778-7800

PHONE: (352) 343-9839
FAX: (352) 343-9473

www.lakegovernment.com

ADDENDUM NO. 2
Date: May 12, 2017
Invitation to Bid (ITB) 17-0226

**REPLACEMENT OF HOT AND COLD WATER PIPING AT THE LAKE COUNTY
SHERIFF ADMINISTRATION BUILDING**

It is the vendor's responsibility to ensure their receipt of all addenda, and to clearly acknowledge all addenda within their initial bid response. Acknowledgement may be confirmed either by inclusion of a signed copy of this addendum with the initial bid response, or by completion and return of the addendum acknowledgement section of the solicitation. Failure to acknowledge each addendum may prevent the bid from being considered for award.

This addendum DOES NOT change the date for receipt of bids or proposals.

The purpose of this addendum is to provide an answer to the one vendor question received within the specified time frame:

Question 1: I would like to ask if you (the county) would prefer Schedule 80 on the hot water piping in the replacement process vs Schedule 40 mainly on hot water due to expansion and contraction as well as expansion joints to be installed in the process of re-piping to avoid any expansion/contraction damage for being an issue as we had a change order on the Jail re-pipe job due to expansion joints not being in the engineering plans. Not sure if that would classify for an addendum prior to bid.

Answer 1: The County hereby specifies Schedule 80 piping for all piping to be installed under the scope of work.

Vendors are reminded to complete plan reviews as and if desired/required.

Acknowledgement of Addendum:

Firm Name: _____ Date: _____
Signature: _____ Title: _____
Typed/Printed Name: _____